



City of Columbus
Mayor Gregory S. Lashutka

Department of Public Utilities

James P. Joyce, P.E., Director

Rule and Regulation No. 92-6
Division of Water
Department of Public Utilities


Date October 26, 1992

SUBJ: WATER SERVICE MATERIAL ON PROPERTIES WITH UNDERGROUND STORAGE FACILITIES


Polyethylene tubing is widely used on 3/4" through 2" water services without any substantial problems. One disadvantage with this material is that certain pollutants can permeate the pipe wall by chemical diffusion and thereby contaminate the water supply.

Therefore, in accordance with Section 1101.02 and Section 1113.01 of the Columbus City Code, the following regulation is hereby established for water services to properties where petroleum products or other health hazard materials are stored in an underground vessel and adjoining properties.

All new and replacement water services, sizes 3/4" through 2", on properties with an underground vessel being used or having previously been used for storage of a petroleum product or other health hazard material shall be constructed with Type K Copper tubing. Any water service to an adjacent property within fifty (50) feet of any such underground vessel shall also be subject to the same material requirements.


John R. Douth, P.E.
Administrator
Division of Water

APPROVED:


James P. Joyce, P.E., Director
Department of Public Utilities

Published in City Bulletin 11/7/92

Utilities Complex

#10 Dublin Road, Columbus, Ohio 43215-9060

Director's Office
Electricity Division
Sewerage and Drainage Division
Water Division

614 645-6141
614 645-8371
614 645-7175
FAX 614 645-3801
614 645-7020
FAX 614 645-8177



Solid Waste Reduction Facility

2500 Jackson Pike
Columbus, Ohio 43223

614 645-3147
FAX 614 645-3654