



RULE AND REGULATION 04-01

February 20, 2004

**Division of Water
Department of Public Utilities**

SUBJECT: MATERIALS FOR WATER SERVICE TAPS

Pursuant to the authority granted under Columbus City Codes, Section 1101, the Director of the Department of Public Utilities hereby adopts, establishes and publishes this rule and regulation, to be effective May 1, 2004. This rule and regulation is in addition to any established requirements that have not been superseded or rescinded by this or any previous act.

APPLICATION:

All water service taps on the Division of Water distribution system. This includes taps in full service contract areas.

DEFINITIONS:

Tap: the connection to the water main and the necessary piping extending from the water main to and including the curb stop or valve and box.

Full Service Contract areas: Brice, Brookside Estates, Dublin, Grandview Heights, Grove City, Groveport, Hamilton Meadows, Hilliard, Marble Cliff, Minerva Park, New Albany, Ridgewood Estates, Riverlea, Urbancrest, Upper Arlington, Valleyview, Village Park, Whitehall, and Worthington.

MATERIAL:

2" and smaller piping:


Piping two (2) inches and smaller shall be composed of Type K soft temper copper tubing conforming in all respects to ASTM B 88 or Federal Specification WW-T-799 from the water main to the curb stop. No other materials shall be permitted for piping two (2) inches and smaller. All other components required for taps shall be in accordance with the most current Construction and Material Specifications manual, unless otherwise approved by the Division of Water Administrator or designee.


| | | | |
|--------------------------------|-----------------------|----------------------|-------------------|
| Utilities Complex | 910 Dublin Road | Columbus, Ohio 43215 | |
| Director's Office | 614/645-6141 | FAX: 614/645-8019 | TDD: 614/645-6454 |
| Sewerage and Drainage Division | 614/645-7175 | FAX: 614/645-3801 | TDD: 614/645-6338 |
| Water Division | 614/645-7020 | FAX: 614/645-8177 | TDD: 614/645-7188 |
| Electricity Division | 3500 Indianola Avenue | Columbus, Ohio 43214 | |
| | 614/645-8371 | FAX: 614/645-7830 | TDD: 614/645-6454 |

R&R 04-01, continued...

3" and larger piping:

Piping three (3) inches and larger shall be in accordance with Section 805.03 of the most current Construction and Material Specifications manual, unless otherwise approved by the Division of Water Administrator or designee.

APPROVED: 
JEFFREY A. HUBBARD, P.E.
ADMINISTRATOR
DIVISION OF WATER

APPROVED: 
CHERYL ROBERTO, ESQ.
DIRECTOR
DEPARTMENT OF PUBLIC UTILITIES