

**Transmission & Distribution**  
**Material & Installation Specification**

**Cable Continuity Test**

**I. Quantity**

The base bid shall include the indicated number of Cable Continuity Test furnished and installed as hereinafter specified.

**II. Material**

A. Equipment - Megger instrument or approved equal.

**III. Installation / Test Procedure**

A. Perform a shield-continuity test on each power cable by ohmmeter method. Log data and submit for approval

CITY OF COLUMBUS DEPT. OF PUBLIC UTILITIES – DIVISION OF POWER CABLE CONTINUITY TEST		
DRAWN BY: AEC	DATE: 01/01/2018	<b>TDMIS-1606</b>
APPROVED: R. SPRITE		
	SHEET 1 of 2	

PLEASE INSERT FORM OF TEST IN THIS PAGE

CITY OF COLUMBUS DEPT. OF PUBLIC UTILITIES – DIVISION OF POWER CABLE CONTINUITY TEST		
DRAWN BY: AEC	DATE: 01/01/2018	TDMIS-1606
APPROVED: R. SPRITE		
	SHEET 2 of 2	