



NOTES:

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
3. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.12.
4. IF CONTAMINATED SOILS ARE ENCOUNTERED DURING EXCAVATION, CEASE DIGGING AND CONTACT THE DIVISION OF WATER DISTRIBUTION ENGINEERING SECTION.

L-1701A Date Created: 1/19/18

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
R.C. Westerfield
 ADMINISTRATOR

1-26-18
 DATE

STANDARD DETAIL
TYPICAL TRENCH
 EXCAVATION & BACKFILL UNDER
 INFLUENCE OF PAVEMENT
 (FOR 2" AND SMALLER WATER TAPS)

