



**NOTES:**

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
3. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.12.
4. IF CONTAMINATED SOILS ARE ENCOUNTERED DURING EXCAVATION, CEASE DIGGING AND CONTACT THE DIVISION OF WATER DISTRIBUTION ENGINEERING SECTION.

L-1701B Date Created: 1/19/18

CITY OF COLUMBUS  
 DEPARTMENT OF PUBLIC UTILITIES  
 DIVISION OF WATER

APPROVED:  
*R.C. Westerfield*  
 ADMINISTRATOR

1-26-18  
 DATE

STANDARD DETAIL  
**TYPICAL TRENCH**  
 EXCAVATION & BACKFILL OUTSIDE  
 INFLUENCE OF PAVEMENT  
 (FOR 2" AND SMALLER WATER TAPS)

