



NOTES:

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
3. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.12.
4. IF CONTAMINATED SOILS ARE ENCOUNTERED DURING EXCAVATION, CEASE DIGGING AND CONTACT THE DIVISION OF WATER DISTRIBUTION ENGINEERING SECTION.

L-6309B Revision Date: 1/19/18

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER
APPROVED: <i>RC Westersfeld</i> 1-26-18 ADMINISTRATOR DATE

STANDARD DETAIL
TYPICAL TRENCH
 EXCAVATION & BACKFILL OUTSIDE
 INFLUENCE OF PAVEMENT
 (FOR 16" DIAMETER WATER MAIN AND SMALLER)

