



NOTES:

Dimensions shall be varied as directed to suit make of valve furnished.

Width shall be as required to allow access to bolts. (6" min.)

When installing horizontal gate valves, the operator shall be set on either the south or east side of the proposed water main.

L-6617.Dwg Revision Date: 1/2/13

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	
APPROVED: <i>R. C. Waterfield</i> ADMINISTRATOR	1-26-18 DATE

STANDARD DETAIL
CONCRETE VALVE SUPPORT
FOR HORIZONTAL
GATE TAPPING VALVE w/BY-PASS

