



ALL WATER TAPS 2 INCHES AND UNDER SHALL BE TYPE "K" COPPER MEETING THE REQUIREMENTS OF SECTION 805.03.

CONTRACTOR SHALL REPLACE ANY DAMAGED CURB BOX ENCOUNTERED IN TRANSFERRING WATER SERVICE LINES AS DETERMINED BY THE ENGINEER. REFER TO THE GENERAL NOTES FOR ESTIMATED CONTINGENCY QUANTITIES WHICH HAVE BEEN INCLUDED IN THE QUANTITY SUMMARY FOR REPLACING DAMAGED CURB BOXES.

ANY CURB BOXES DAMAGED BY THE CONTRACTOR SHALL BE REPLACED BY THE CONTRACTOR AT NO ADDITIONAL COST TO THE CITY.

* FOR REFERENCE IN PLACING NEW CURB STOPS AND CURB BOXES SEE "L-9901".

** PIPE SHALL BE COPPER TUBING SIZE (C.T.S.)

L-7102B.Dwg Revision Date: 1/19/18

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	STANDARD DETAIL ITEM 805 WATER SERVICE LINE TRANSFER	
APPROVED: ADMINISTRATOR	1-26-18 DATE	