



*** NOTE:**
 For reference in placing new curb stops
 and relocated curb boxes see L-9901.

**** NOTE:**
 Should Poly tubing, Galvanized or Lead
 material be encountered the entire Water Tap
 shall be replaced w/ Copper from the
 existing Corporation Stop to the new Curb
 Stop. Pipe Shall Be Copper Tubing Size (C.T.S.).

L-7102C.Dwg Revision Date: 1/19/18

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	
APPROVED: <i>RC Westerful</i>	1-26-18
ADMINISTRATOR	DATE

STANDARD DETAIL
 WATER TAP RELOCATION

