



NOTES:

- Vertical Bends Shall Be 11 1/4", 22 1/2" or 45"
- Where "D" is 18" or Less, a Mechanical Joint Ductile Iron Offset may be used in lieu of the two Vertical Bends and the Inclined Nipple, as Approved by the Engineer.
- Fire Hydrants shall be set a minimum of 6' from all Driveway Radius Returns.
- All Bends are to be Included in the Cost of Item 801.
- No Hydrant Extensions Will be Permitted without Prior Approval from DOW.

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
RC Westphal
 ADMINISTRATOR

1-26-18
 DATE

STANDARD DETAIL
TYPICAL HYDRANT SETTING
 (TO ELIMINATE EXCESSIVE BURY)

