

PCCP Spigot

Prestressed Concrete Pipe

L301B x L301 Flg. Adapter (Min. 6'-0") (See Notes 1 & 2)

Butterfly Valve Flg. x Flg.

Concrete Valve Support (As per L-6306)

PCCP Bell

L301S x L301 Flg. Adapter (Min. 6'-0") (See Notes 1 & 2)

Prestressed Concrete Pipe

Note:

1) Add Snap Ring or Harness Restrained Joints and Anchored M.J.S. Joints to Adapters located in restrained areas when Restrained Joints are required on Plans.

2) Paint all exposed steel with Hi-Build White Epoxy Paint Coating.

L-7602.Dwg Revision Date: 2/9/12

CITY OF COLUMBUS
DEPARTMENT OF PUBLIC UTILITIES
DIVISION OF WATER

APPROVED:
RC Westerfield
ADMINISTRATOR
1-26-12
DATE

STANDARD DETAIL
CONCRETE PIPE
VALVE PIPING CONNECTION

