



▲ Solid Concrete Supports under all Valves and Meter Flanges, Solid Concrete Blocks may be used as well (Typical) (Shim with Hardwood as Needed)

L-9002G.Dwg Revision Date: 4/24/13

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER
 APPROVED:
RC Westerfield 1-26-18
 ADMINISTRATOR DATE

STANDARD DETAIL
 TYPICAL BACKFLOW
 PREVENTER SETTING
 (INSIDE BUILDING or HOT BOX)
 2" THRU 12" METERS

