

NOTES:

See Detail L-6317B for vault details not shown.
 Refer to L-6317D for additional information.

Meter Size	Inside Vault Dimension		Meter Length*		Min. Wall Clearance	
	Length	Width	Combo	Domestic	A	B
3"	8'-0"	5'-0"	2'-9"	2'-0"	2'-6"	2'-6"
4"	8'-0"	6'-0"	2'-9"	2'-5"	3'-0"	3'-0"
6"	10'-0"	8'-0"	3'-9"	3'-9"	4'-0"	4'-0"
8"	11'-0"	9'-0"	4'-5"		4'-6"	4'-6"
10"	15'-0"	10'-0"	5'-8"		5'-0"	5'-0"
12"	15'-0"	10'-0"	5'-8"		5'-0"	5'-0"

* DCDA shall be A.S.S.E. #1048 Approved and length will vary by manufacturer. Meter length includes meter, spool piece, and test port as shown. Meter, spool piece and test port provided by DOW.

Dimensions shown are face to face. Allowances must be provided for the thickness of the gaskets to be used.


An approved above ground enclosure may be used for DCDA's and RPDA's only.

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
Dorella Pottenshi
 ADMINISTRATOR

5/17/21
 DATE

STANDARD DETAIL
 METER VAULT SETTING
 PLAN VIEW
 3" THRU 12" METERS



L-6317A.dwg Revision Date: 4/21/21