



See detail L-6317A for vault details not shown on this detail.

No connections permitted between R/W service valve and the meter.

No Meter Vault shall be installed in any paved area without the expressed approval of the Division of Water Distribution Engineering Office.

All Valves 3" and larger, inside the vault, shall be gate valves with outside screw and yoke assemblies (O.S. & Y.).

The Vault Floor shall be a min. of 18" above the flow line of the Drainage Ditch or Storm Sewer. Use of a Sump Pump in lieu of providing adequate drainage is not permitted. Where adequate drainage is not available or proves to be inadequate, a Sump Pump may be allowed, upon prior approval, by the Division of Water Distribution Engineering Office. See Standard Detail L-9402.

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
R.C. Westfield 2-20-18
 ADMINISTRATOR DATE

STANDARD DETAIL
 METER VAULT SETTING
 SECTION VIEW
 2" thru 10" x 12" METERS

L-6317B

L-6317B.Dwg Revision Date: 2/7/18