


See detail L-6317A for vault details not shown.

Refer to L-6317D for additional information.

The Vault Floor shall be a min. of 18" above the flow line of the Storm Sewer or Drainage Ditch. Use of a Sump Pump in lieu of providing adequate drainage is not permitted. Where adequate drainage is not available or proves to be inadequate, a Sump Pump may be allowed, upon prior approval, by the Division of Water Distribution Engineering Office. See Standard Detail L-9402.

L-6317B.Dwg Revision Date: 4/21/21

| | | |
|---|--|---|
| CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER | STANDARD DETAIL METER VAULT SETTING SECTION VIEW 3" thru 12" METERS |  |
| APPROVED:  ADMINISTRATOR | | |

5/17/21
DATE