

NOTE:
 Refer to Division of Water Standard Details "L-8503", "L-9002A" & "L-9002B" for additional information.



NOTE:
 DOW provided radio transmitter shall be installed outside building per L-6101.

5/8", 3/4" or 1" Meter to be Installed By Division of Water after test of Back Flow Preventor.

Slab/Crawl Space (24" Max.)
 Basement (48" Max.)

Sleeving, refer to Division of Water Rule and Regulation 01-05

L-9002E.Dwg Revision Date: 1/25/18

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	STANDARD DETAIL SCHEMATIC DRAWING OF 5/8" THRU 1" METER WITH BACKFLOW PREVENTER	
APPROVED:  ADMINISTRATOR		

1-26-18
 DATE