

TDMIS INDEX

TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS	TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS
1-99 GENERAL							
1	WOOD POLES	1/1/2018	6	203	ALLEY ARM CONSTRUCTION (TWO PHASE CONSTRUCTION) *	1/1/2018	1
7	OVERHEAD DISTRIBUTION CIRCUIT GROUNDING	1/1/2018	3	204	LARGE LINE ANGLES, 60°-90° (TWO PHASE CONSTRUCTION) *	1/1/2018	1
8	OVERHEAD TRANSMISSION CIRCUIT GROUNDING, 3'-0" INSULATION SPACING	1/1/2018	2	206	DEADEND ASSEMBLY	1/1/2018	4
9	OVERHEAD TRANSMISSION CIRCUIT GROUNDING, 6'-0" INSULATION SPACING	1/1/2018	2	207	DOUBLE DEADEND (TWO PHASE CONSTRUCTION) *	1/1/2018	1
10	WOOD CROSSARM	1/1/2018	12	208	TWO PHASE BRANCH *	1/1/2018	1
11	WOOD CROSSARM (STEEL BRACES)	1/1/2018	12	209	TWO WAY BUCK (TWO PHASE CONSTRUCTION) *	1/1/2018	1
20	PIN AND PIN INSULATOR	1/1/2018	2	210	FOUR WAY CORNER (TWO PHASE CONSTRUCTION) *	1/1/2018	1
22	MISCELLANEOUS LINE HARDWARE	1/1/2018	3	300-399 THREE PHASE CONSTRUCTION - SPACER CABLE			
23	BOLTED CONNECTOR ASSEMBLY	1/1/2018	3	300	14" SPACER CABLE TANGENT BRACKET, TANGENT 5° OR LESS	1/1/2018	22
24	COPPER CONDUCTOR HAND-MADE INSULATOR TIES	1/1/2018	3	301	24" SPACER CABLE TANGENT BRACKET, TANGENT 5° OR LESS	1/1/2018	2
25	ALUMINUM CONDUCTOR HAND-MADE INSULATOR TIES	1/1/2018	2	302	14" SPACER CABLE TANGENT BRACKET WITH ANTI-SWAY BRACKET, TANGENT 5° OR LESS	1/1/2018	2
26	DISTRIBUTION CUTOUT	1/1/2018	2	303	24" SPACER CABLE TANGENT BRACKET WITH ANTI-SWAY BRACKET, TANGENT 5° OR LESS	1/1/2018	2
27	DISTRIBUTION ARRESTER APPLICATOIN	1/1/2018	3	304	SPACER CABLE DEADEND ON CROSSARM	1/1/2018	2
28	HOT LINE CLAMP AND RISER ASSEMBLY	1/1/2018	3	305	SPACER CABLE TO SPACER CABLE DOUBLE DEADEND ON CROSSARM	1/1/2018	2
29	LINE FUSES *	1/1/2018	1	306	SPACER CABLE TO OPEN WIRE DOUBLE DEADEND ON CROSSARM	1/1/2018	2
100-199 GUYING				308	SPACER CABLE ANGLE BRACKET, 5 TO 60 DEGREES	1/1/2018	2
100	SINGLE DOWN GUY & ANCHOR WITH INSULATOR	1/1/2018	3	309	SPACER CABLE ANGLE BRACKET, OVER 60 DEGREES	1/1/2018	2
101	DOUBLE DOWN GUY & ANCHOR WITH INSULATOR	1/1/2018	3	310	SPACER CABLE SPACERS	1/1/2018	2
104	SPAN GUY	1/1/2018	2	311	MESSENGER ATTACHMENT TO CROSSARM	1/1/2018	2
105	SPAN GUY WITH INSULATOR	1/1/2018	2	400-499 THREE PHASE CONSTRUCTION - CROSSARM			
106	SPAN GUY WITH INSULATOR AND GUY PLATE	1/1/2018	2	400	TANGENT AND ANGLES UP TO 5 DEGREES (TRHEE PHASE CONSTRUCTION) *	1/1/2018	1
109	DOWN GUY FITTINGS	1/1/2018	2	401	SMALL ANGLES, 5°-20° (THREE PHASE CONSTRUCTION) *	1/1/2018	1
110	GUY WIRE	1/1/2018	2	402	MEDIUM LINE ANGLES, 20°-60° (THREE PHASE CONSTRUCTION) *	1/1/2018	1
111	FIBERGLASS GUY INSULATOR AND GRIPS	1/1/2018	2	403	ALLEY ARM CONSTRUCTION (THREE PHASE CONSTRUCTION)	1/1/2018	1
112	SCREW ANCHOR	1/1/2018	2	404	LARGE LINE ANGLES, 60°-90° (THREE PHASE CONSTRUCTION) *	1/1/2018	1
113	POLE KEY	1/1/2018	2	405	PRIMARY NEUTRAL ASSEMBLY	1/1/2018	2
114	PUSH POLE BRACE FITTING	1/1/2018	2	406	DEADEND ASSEMBLY	1/1/2018	4
115	EXPANDING ANCHOR	1/1/2018	3	407	DOUBLE DEADEND (THREE PHASE CONSTRUCTION) *	1/1/2018	1
200-299 TWO PHASE CONSTRUCTION							
200	TANGENT AND ANGLES UP TO 5 DEGREES (TWO PHASE CONSTRUCTION) *	1/1/2018	1				
201	SMALL ANGLES, 5°-20° (TWO PHASE CONSTRUCTION) *	1/1/2018	1				
202	MEDIUM LINE ANGLES, 20°-60° (TWO PHASE CONSTRUCTION) *	1/1/2018	1				

* TDMIS IS FOR REFERENCE ONLY

CITY OF COLUMBUS, OHIO DEPT. OF PUBLIC UTILITIES - DIVISION OF POWER	
TDMIS INDEX	
DRAWN BY: AEC	DATE: 01/01/2018
APPROVED: R. SPRITE	
SCALE: NONE	SHEET: 1 OF 3
TDMIS-0	

TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS	TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS
408	THREE PHASE DEADEND AND TWO PHASE CONTINUATION, 0°-5° *	1/1/2018	1	902	GROUP OPERATED AIR BREAK SWITCH	1/1/2018	3
409	THREE PHASE BRANCH, 20°-90° *	1/1/2018	1	903	GROUP OPERATED AIR BREAK SWITCH, WITH HOOKSTICK OPERATOR	1/1/2018	3
410	TWO WAY BUCK (THREE PHASE CONSTRUCTION) *	1/1/2018	1	905	THREE PHASE RECLOSER INSTALLATION - 600 AMP MAX	1/1/2018	4
411	FOUR WAY CORNER (THREE PHASE CONSTRUCTION)	1/1/2018	1	906	THREE PHASE DEADEND RISER WITH RECLOSER AND DISCONNECT SWITCHES	6/1/2018	1
412	TWO POLE "H" FRAME *	1/1/2018	1	908	UNDERARM SWITCH	1/1/2018	2
<u>500-599 SECONDARY</u>				<u>1000-1099 UNDERGROUND STRUCTURE</u>			
500	SECONDARY, NEUTRAL AND MESSENGER SUPPORT ASSEMBLY	1/1/2018	2	1000	PVC CONDUIT SIZING GUIDELINE *	1/1/2018	1
502	SECONDARY AND NEUTRAL DEADEND ASSEMBLIES (ACSR/ALUMINUM)	1/1/2018	2	1001	RISER POLE*	8/30/2018	2
503	SERVICE DROP ATTACHMENTS AT BUILDING	1/1/2018	2	1004	CLEARANCE FOR JOINT USE DIRECT BURIED TELECOM & SUPPLY CABLE/CONDUIT *	1/1/2018	2
<u>600-699 CLEARANCE</u>				1005	CONCRETE PAD FOR THREE PHASE PADMOUNT TRANSFORMER 75 KVA THRU 500 KVA	1/1/2018	2
600	JOINT USE TELECOMMUNICATION EQUIPMENT AND CABLES *	1/1/2018	1	1006	CONCRETE PAD FOR THREE PHASE PADMOUNT TRANSFORMER 750 KVA THRU 2500 KVA	1/1/2018	2
601	LIGHTING FACILITIES *	1/1/2018	1	1009	FIBERGLASS FLAT PAD FOR SINGLE PHASE TRANSFORMER	1/1/2018	2
602	CLEARANCE BETWEEN DOWN GUY & LINE CONDUCTORS ATTACHED TO THE SAME STRUCTURES *	1/1/2018	1	1010	PRIMARY METERING ENCLOSURE CONCRETE FOUNDATION - 200 AMP MAX	1/1/2018	2
603	CLEARANCE BETWEEN DOWN GUY & LINE CONDUCTORS ATTACHED TO DIFFERENT STRUCTURES *	1/1/2018	1	1011	PRIMARY METERING ENCLOSURE CONCRETE FOUNDATION - 600 AMP MAX	1/1/2018	3
604	CLEARANCE BETWEEN SPAN GUY AND LINE CONDUCTORS PARALLEL TO EACH OTHER ATTACHED TO THE SAME STRUCTURE *	1/1/2018	1	1012	4'X4' PULL BOX	1/1/2018	3
605	CLEARANCE BETWEEN SPAN GUY AND LINE CONDUCTORS TRAVERSE TO EACH OTHER ATTACHED TO THE SAME STRUCTURE *	1/1/2018	1	1013	CONCRETE DUCT BANK	1/1/2018	5
606	SERVICE DROP CABLE CLEARANCE FOR CONDUCTORS *	1/1/2018	1	1014	PRECAST VAULT	1/1/2018	16
<u>700-799 REGULATORS AND CAPACITORS</u>				1015	PRECAST MANHOLE	1/1/2018	10
<u>800-899 OVERHEAD TRANSFORMERS</u>				1016	SWITCHGEAR MANHOLE	1/23/2018	9
800	OVERHEAD POLE TYPE TRANSFORMER DOP PART NUMBERS *	1/1/2018	1	<u>1100-1199 UNDERGROUND CONNECTORS AND COMPONENTS</u>			
801	"T" LINK TRANSFORMER FUSING *	1/1/2018	1	1100	LOADBREAK ELBOW - 200 AMP	1/1/2018	3
802	SECONDARY TRANSFORMER CONNECTION ALUMINUM CONNECTION *	1/1/2018	1	1101	LOADBREAK CONNECTOR - 200 AMP	1/1/2018	2
803	CLUSTER TYPE MOUNTING BRACKET	1/1/2018	1	1102	LOADBREAK BUSHING INSERTS 200 AMP MAX	1/1/2018	2
804	SINGLE PHASE OVERHEAD TRANSFORMER	1/1/2018	5	1103	600 AMP DEADBREAK ELBOW SYSTEM	1/1/2018	2
<u>900-999 SECTIONALIZING</u>				1104	ELBOW SURGE ARRESTER - 200 AMP	1/1/2018	2
900	THREE PHASE PRIMARY LINE SECTIONALIZING - 200 AMP *	1/1/2018	1	1105	CABLE SPLICE	1/1/2018	2
901	THREE PHASE PRIMARY LINE SECTIONALIZING - 600 AMP *	1/1/2018	1	1106	CABLE GRIPS	1/1/2018	3

* TDMIS IS FOR REFERENCE ONLY

CITY OF COLUMBUS, OHIO DEPT. OF PUBLIC UTILITIES - DIVISION OF POWER		
TDMIS INDEX		
DRAWN BY: AEC	DATE: 01/23/2018	TDMIS-0
APPROVED: R. SPRITE		
SCALE: NONE	SHEET: 2 OF 3	

TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS	TDMIS #	DESCRIPTION	LAST REVISION DATE	NUMBER OF PAGES IN TDMIS
1200-1299 PADMOUNT TRANSFORMERS				1603	CONDUCTOR SAFETY POLICY	1/1/2018	1
1200	PADMOUNT TRANSFORMER PART NUMBERS *	1/1/2018	1	1604	HOLD CARD SYSTEM	1/1/2018	1
1201	SINGLE PHASE PADMOUNT TRANSFORMER	1/1/2018	4	1605	HIGH POTENTIAL POWER CABLE TEST	1/1/2018	2
1202	THREE PHASE PADMOUNT TRANSFORMER STANDARD CONNECTION, 6 PRIMARY BUSHINGS	1/1/2018	5	1606	CABLE CONTINUITY TEST	1/1/2018	2
1205	PADMOUNT URD SINGLE PHASE TRANSFORMER-SECONDARY CONNECTION	1/1/2018	1	1607	GROUND ROD TEST	1/1/2018	2
1206	SINGLE PHASE DEAD-FRONT PADMOUNT TRANSFORMER	1/1/2018	1	1608	SIGNAGE FOR CIP PROJECTS	1/1/2018	3
1209	480 VOLT SERVICE SINGLE PHASE DEAD-FRONT PADMOUNT TRANSFORMER	1/1/2018	1	2000	MATERIAL LIST	8/30/2018	1
1211	120/208 OR 277/480 VOLT WYE SECONDARY WIRING	1/1/2018	1				
1212	480 VOLT THREE WIRE SECONDARY WIRING	1/1/2018	1				
1213	CIRCLE GROUND ASSEMBLY	1/1/2018	3				
1300-1399 UNDERGROUND CABLE RISERS							
1300	SINGLE PHASE PRIMARY RISER - 200 AMP (ONE PHASE CONDUCTOR)	1/1/2018	2				
1301	SINGLE PHASE PRIMARY RISER - 200 AMP (TWO PHASE CONDUCTOR)	1/1/2018	2				
1302	THREE PHASE PRIMARY RISER - 200 AMP	1/1/2018	2				
1303	THREE PHASE PRIMARY RISER - 600 AMP	1/1/2018	2				
1400-1499 UNDERGROUND ENCLOSURES AND SWITCHES							
1400	SINGLE PHASE PRIMARY ENCLOSURE - 200 AMP	1/1/2018	3				
1401	THREE PHASE PRIMARY ENCLOSURE - 200 AMP	1/1/2018	3				
1402	NON-METALLIC SERVICE PEDESTAL	1/1/2018	3				
1403	NON-METALLIC SUBSURFACE SERVICE ENCLOSURE	1/1/2018	3				
1405	SF6 SWITCH	1/1/2018	4				
1406	PADMOUNT SWITCH	1/1/2018	6				
1500-1599 WIRE & CABLE							
1500	OVERHEAD CONDUCTOR, SPACER CABLE	1/1/2018	2				
1501	OVERHEAD CONDUCTOR, ACSR AND ALUMINUM	1/1/2018	3				
1502	OVERHEAD CONDUCTOR, COPPER	1/1/2018	3				
1510	UNDERGROUND CABLE	1/1/2018	3				
1600-1699 POLICIES & PROCEDURES							
1600	EXISTING OVERHEAD TRANSMISSION & DISTRIBUTION SYSTEM REMOVAL	1/1/2018	2				
1601	EXISTING UNDERGROUND DISTRIBUTION SYSTEM REMOVAL	1/1/2018	2				
1602	MINIMUM STANDARDS	1/1/2018	4				

* TDMIS IS FOR REFERENCE ONLY

CITY OF COLUMBUS, OHIO DEPT. OF PUBLIC UTILITIES - DIVISION OF POWER	
TDMIS INDEX	
DRAWN BY: AEC	DATE: 01/01/2018
APPROVED: R. SPRITE	
SCALE: NONE	SHEET: 3 OF 3
TDMIS-0	