

City of Columbus: Division of Power
Inspection Checklist For Street Lighting Construction

Form # 1 of 3
(Poles)

To Be Completed By Inspector (City of Columbus Design & Construction, Franklin County, ODOT, Private Co. etc.)

Project: _____ Drawing: _____

Contractor: _____ Date of Installation: _____

Inspector / Agency: _____ Date of Inspection: _____

MIS #	Item	Station #	Station #	Station #	Station #	Station #
	FOUNDATION					
	Location Per Plan					
	Depth of Fondation					
	Concrete Per Spec (Item 499)					
	Ground Rod 10'					
	Anchor Bolt Size					
	Cap Dimmensions					
	1/2" Chamfer					
	Sidewalk / Yard Repair					
	LIGHT POLE					
	Location Per Plan					
	Style Per Plan					
	Hand Hole Position Corrcrect					
	Pole Grounded					
	Pole Plumb					
	POLE WIRING					
	# 6 Ground Wire (Soft Drawn)					
	3 Amp KTK Fuse (100-250 Watt)					
	6 Amp KTK Fuse (400 Watt)					
	(1) YC2C4 Crimp Connector					
	(2) YC4C4 Crimp Connector					
	Luminaire Wire Black #10 AWG Type XHHW					
	Luminaire Wire White #10 AWG Type XHHW					
	Luminaire Wire Green #10 AWG Type XHHW					
	LUMINAIRE					
	Luminaire Works					
	Style Per Plan					
	Luminaire is Plumb					
	Luminaire Aimed Correctly					
	TESTING					
	Tic Trace Completed					
	OHMS Reading					

MIS-189
10/4/2017

By placing check marks within this document, the person performing the inspection is confirming that all material within the installation conforms to the latest version of both the City of Columbus CMS book, and MIS specifications.

MIS-4

CITY OF COLUMBUS, OHIO DEPT. OF PUBLIC UTILITIES - DIVISION OF POWER		
INSPECTION CHECKLIST		
DRAWN BY: BEN	DATE: 1/1/2018	
APPROVED: <i>Amy A. Wilfong</i>		
SCALE: NONE	SHEET: 1 OF 1	4