



NOTES:

GUY SHALL BE INSULATED OR BONDED TO THE GROUND.

GUY GUARD SHALL BE USED IN EXPOSED LOCATIONS SUCH AS DRIVEWAYS, SIDEWALKS, AND PARKING LOTS.

- NOTE -

MINIMUM HEIGHT ACROSS OR ALONG SIDEWALKS IS 9.5', ACROSS STREETS IS 15.5' ACROSS RAILROADS IS 23.5' (PER 2023 NESC TABLE 232-1)

I. MATERIALS

- A. THE POLE, IF REQUIRED, SHALL BE PAID FOR UNDER A SEPARATE ITEM.
- B. ALL HARDWARE SHALL BE HOT DIPPED GALVANIZED STEEL.

II. INSTALLATION

- THE SPAN GUY SHALL BE INSTALLED AS INDICATED.
- A. GUY TENSION SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF THE LINE.
 - B. BRACING DOWN GUY OR POLE KEY ANCHOR SHALL BE INSTALLED ON THE GUY POLE AS SHOWN IN THE CONTRACT DRAWING OR AS DIRECTED BY THE ENGINEER.
- THE DOWN GUY OR POLE KEY ANCHOR SHALL BE PAID FOR AS SEPARATE ITEMS.

III. BASIS OF PAYMENT

ITEM	UNIT	DESCRIPTION
MIS-53	EACH	SPAN GUY ASSEMBLY WITH STUB

ITEM	QTY	DESCRIPTION
1	2 EA.	HOOK, GUY, FOR 5/8" OR 3/4" BOLT
2	2 EA.	BOLT, MACHINE 5/8" X 12"
3	2 EA.	WASHER, CURVED, SQUARE, 13/16" HOLE
4	2 EA.	WASHER, SPRING LOCK, 13/16" HOLE
5	2 EA.	GRIP GUY, FOR 3/8" STRAND
6	AS REQ'D	WIRE GUY, 3/8" HIGH STRENGTH 7 STRAND STEEL
7	1 EA.	POLE, IF SPECIFIED

<h1>MIS-53</h1>	DEPARTMENT OF PUBLIC UTILITIES - DIVISION OF POWER CITY OF COLUMBUS, OHIO		
	SPAN GUY ASSEMBLY WITH STUB		
	DRAWN BY: SAW	DATE: 12/7/23	
	APPROVED: <i>Jodi Stefanik</i>		
SCALE: NONE	SHEET: 1 OF 1	53	