

I. MATERIALS

THE ALUMINUM POLE SHALL BE AS FOLLOWS:

THE SHAFT SHALL BE A ONE PIECE, ROUND, TAPERED ALUMINUM TUBE, SATIN GROUND, HAVING A BASE WELDED TO THE LOWER END AND COMPLETE WITH BOLTS, ALUMINUM TRANSFORMER BASE, AND 2-1/2" DIAMETER BY 5'-6" SCHEDULE 80 PIPE BRACKET WITH 6" X 2" NPS SLIP FITTER AND CHANNEL SCROLL. THE COMPLETE UNIT SHALL BE DESIGNED FOR WIND LOADING OF 90 MILES PER HOUR, THE SHAFT SHALL HAVE NO LONGITUDINAL OR CIRCUMFERENTIAL WELDS EXCEPT AT THE LOWER END JOINING THE SHAFT TO THE BASE. THE SHAFT SHALL BE 8" X 4.5" X APPROXIMATELY 27'-4" WITH MINIMUM WALL THICKNESS OF 0.156 INCH. THE SHAFT SHALL HAVE A TRUE CONTINUOUS TAPER EXCEPT FOR THE BOTTOM SECTIONS WHICH MAY BE STRAIGHT. NO MORE THAN 40 PER CENT OF THE TOTAL SHAFT SHALL BE STRAIGHT. THE TOP OF THE SHAFT SHALL BE EQUIPPED WITH A CAST ALUMINUM REMOVABLE POLE TOP HELD SECURELY IN PLACE BY MEANS OF SET SCREWS. THE POLE SHALL BE FURNISHED WITH BOLT COVERS.

THE ALUMINUM TRANSFORMER BASE SHALL BE 17" HIGH, 15-3/8" SQUARE AT THE BASE AND 13-1/8" SQUARE AT THE TOP. THE DOOR SHALL BE ATTACHED TO THE BASE WITH A STAINLESS STEEL PIANO HINGE. THE HINGE SHALL BE PLACED AT THE TOP OF THE DOOR AND ATTACHED TO THE BASE AND THE DOOR WITH STAINLESS STEEL RIVETS. THE DOOR SHALL BE HELD IN PLACE WITH A TAMPER RESISTANT FASTENER AT THE BOTTOM. EACH BASE SHALL BE PROVIDED WITH FOUR (4) LOOSE BEARING PLATES AND NUTS TO FASTEN THE BASE DOWN TO THE ANCHOR BOLTS. THE TRANSFORMER BASE SHALL FASTEN TO THE SHAFT ANCHOR BASE BY FOUR (4) LOOSE BEARING PLATES AND FOUR (4) HOT DIPPED GALVANIZED HEX HEAD STEEL MACHINE BOLTS AND NUTS. ALL BEARING PLATES SHALL BE HOT DIPPED GALVANIZED. A 1/2"-13 UNC TAPPED HOLE SHALL BE PROVIDED FOR A GROUNDING LUG.

FOUR (4) 1"x36"+4" HIGH STRENGTH, HOT DIPPED GALVANIZED, HOOKED STEEL ANCHOR BOLTS, FITTED WITH A HEX NUT, SHALL BE FURNISHED WITH THE POLES. EACH ANCHOR BOLT BE THREADED AT THE TOP END. THREADED ENDS AND ALL NUTS SHALL BE GALVANIZED. ANCHOR BOLTS SHALL BE CAPABLE OF RESISTING AT YIELD STRENGTH STRESS THE BENDING MOVEMENT OF THE SHAFT AT ITS YIELD STRENGTH STRESS.

ALL HARDWARE (BOLTS, NUTS, AND WASHERS—BUT NOT INCLUDING ANCHOR BOLTS) NOT OTHERWISE SPECIFICALLY DESIGNATED IN THIS SPECIFICATION SHALL BE ALUMINUM OR STAINLESS STEEL (AT THE OPTION OF THE SUPPLIER). POLE SHAFTS AND TENONS SHALL BE TIRE-WRAPPED WITH A HEAVY WATER RESISTANT PAPER FOR PROTECTION DURING SHIPMENT AND INSTALLATION.

ALL ALUMINUM SURFACES ON THE POLE SHALL BE ROTARY SANDED TO A SATIN GROUND FINISH AND BRACKETS SHALL BE ETCHED TO A MATTE FINISH. THE SHAFT, BRACKET, BOLT COVERS AND TRANSFORMER BASE SHALL BE FINISHED

BLACK OR GAHANNA GREEN II (COLOR SPECIFICATION PROTECH #73737-042), AS SPECIFIED. THE FINISH SHALL BE AN ELECTRO-STATICALLY APPLIED POLYESTER OR URETHANE POWDER COAT, OVEN CURED AND BONDED AT APPROXIMATELY 400 DEGREES F, TO A DRY FILM THICKNESS OF 2-4 MILS.

THE COMPLETE POLE SHALL BE HAPCO #17965 P42 OR HAPCO #74135-001 P2 OR AN APPROVED EQUAL IN DESIGN, QUALITY AND PERFORMANCE

II. INSTALLATION

THE POLES AND BASES SHALL BE SET ON THE FOUNDATIONS AND SECURELY ANCHORED TO THE ANCHOR BOLTS. POLE BASES SHALL BE PROPERLY PLUMBED BY MEANS OF METAL SHIMS. AFTER ERECTION, EACH LIGHT POLE SHALL BE ADEQUATELY GROUNDED, AND HAVE TRANSFORMER BASE DOORS FASTENED IN PLACE.

III. BASIS OF PAYMENT

ITEM	UNIT	DESCRIPTION
MIS-305	EACH	POLE, ALUMINUM, 6' BRACKET, T-BASE, 31' MOUNTING HEIGHT, BLACK (TEARDROP LUMINAIRE)
MIS-305	EACH	POLE, ALUMINUM, 6' BRACKET, T-BASE, 31' MOUNTING HEIGHT, GREEN (TEARDROP LUMINAIRE)

MIS-305	DEPARTMENT OF PUBLIC UTILITIES - DIVISION OF POWER CITY OF COLUMBUS, OHIO		
	POLE, ALUMINUM, 6' BRACKET, T-BASE, 31' MOUNTING HEIGHT BLACK/GREEN (TEARDROP)		
	DRAWN BY: BEN	DATE: 1/1/2018	
	APPROVED: <i>[Signature]</i>		
SCALE: NONE	SHEET: 1 OF 1	305	