

I. REMOVAL

THE OLD FOUNDATION SHALL BE ENTIRELY REMOVED TO MAKE ROOM FOR THE NEW FOUNDATION. IF A NEW FOUNDATION IS NOT REQUIRED, THE FOUNDATION SHALL BE REMOVED TO AT LEAST ONE FOOT BELOW THE GROUND SURFACE AND THE HOLE BACKFILLED. THE BACKFILL SHALL BE PLACED PER CITY OF COLUMBUS CONSTRUCTION AND MATERIAL SPECIFICATIONS.

THE CONCRETE SHALL BE DISPOSED OF BY THE CONTRACTOR IN ACCORDANCE WITH CITY OF COLUMBUS CONSTRUCTION AND MATERIAL SPECIFICATIONS.

IF THE OLD FOUNDATION IS LOCATED IN A SIDEWALK, THE FOUNDATION SHALL BE REMOVED AND THE SECTION OF THE SIDEWALK SHALL BE REPLACED. REFER TO CITY OF COLUMBUS, DEPARTMENT OF PUBLIC SERVICE STD DWG 1441 FOR SIDEWALK REPLACEMENT.

II. BASIS OF PAYMENT

ITEM	UNIT	DESCRIPTION
MIS-900	EACH	FOUNDATION REMOVAL

MIS-900	DEPARTMENT OF PUBLIC UTILITIES - DIVISION OF POWER CITY OF COLUMBUS, OHIO		
	FOUNDATION REMOVAL		
	DRAWN BY: BEN	DATE: 1/1/2018	
	APPROVED: <i>Amy R. Wilk</i>		
SCALE: NONE	SHEET: 1 OF 1	900	