

CLEAN AND RELAMP LPS LUMINAIRE

I. Quantity

The base bid shall include the indicated number of LPS luminaires cleaned and relamped.

II. Material

The lamp shall be the wattage indicated on the drawing and have a rated life of 18,000 hours. The lamp shall be equal in quality and performance to those manufactured by Lighting Company.

III. Task

The refractor shall be removed from the luminaire and thoroughly washed in a suitable detergent rinsed and dried. Dirt and debris shall be removed from the luminaire housing. The reflector shall be cleaned with suitable spray type cleaning agent. Care shall be exercised to not damage the surface of the reflector.

The luminaire shall be re-assembled and the new lamps installed.

IV. Quotation

The cleaning and re-lamping LPS luminaire as hereinbefore specified shall be quoted as a unit price each in the appropriate place in this document.