

Construction Industry Communication # 01

From: Amit Ghosh, Chief Building Official

Re: Grease Interceptors and Required Direct & Indirect Connections to the Sanitary Building Drainage System

Requirements: Section 1003.3.1 of the Ohio Plumbing Code (OPC) Grease interceptors and automatic grease removal devices required. A grease interceptor or automatic grease removal device shall be required to receive the drainage from fixtures and equipment with grease-laden waste located in food preparation areas, such as in restaurants, hotel kitchens, hospitals, school kitchens, bars, factory cafeterias and clubs. Fixtures and equipment shall include pot sinks, prerinse sinks; soup kettles or similar devices; wok stations; floor drains or sinks into which kettles are drained; automatic hood wash units and dishwashers without prerinse sinks. Grease interceptors and automatic grease removal devices shall receive waste only from fixtures and equipment that allow fats, oils or grease to be discharged.

The City of Columbus Department of Building & Zoning Services (BZS) determines if grease separation is required at a facility for the Department of Sewers and Drains (DOSD). A grease determination form must be completed for any of the following reasons and sent to greaseinterceptor@columbus.gov :

1. New food service facility
2. Menu Changes at existing food service facilities
3. Alteration, Addition or Renovation at food service facility

Please contact BZS at 614-645-3984 or email greaseinterceptor@columbus.gov for questions concerning grease separation or grease interceptor installation requirements.

Memorandum: DOSD will consider variances from the GREASE INTERCEPTOR requirement based on information provided, using the Variance Request Form below. The Industrial Wastewater Pretreatment Group (IWPG) processes all Interceptor Variance Requests.

Interceptor Variance Approvals may be granted based on the existence of one or more of the following criteria:

- Inadequate elevation to route flow to an outside interceptor and either direct it back to the service lateral by gravity or direct it to the City sewer by gravity.
- Inadequate property size for installation of an outside (gravity) interceptor.
- The location would require underground utilities to be relocated.
- The facility is located in an interior tenant space within a mall.

While the IWPG will consider Variance Requests for other reasons, hardship requests based on the cost of installation will **not** be considered for Variance Approval.

Ohio Administrative Code (OAC) 3745-42-02, (B), (3) applies to the installation of outside interceptors unless a Permit to Install is obtained from the Ohio EPA.

Note: it is acceptable to install inside grease removal devices in addition to a required outside grease interceptor.

The following instructions provide guidance when submitting a Variance Request. Please read all of the instructions - an incomplete submittal will delay review and may result in an unnecessary denial of the request. The Parcel Identification Number should be included in the Variance Request. For a variance to be approved, the reason(s) must be clearly documented. A drawing or sketch with dimensions and elevations of everything to be considered is usually necessary. Pictures may be useful.

Applicants may submit their variance request by fax to (614) 645-0227, by email to FOG@Columbus.gov or delivery to the address listed below. Applicants are encouraged to contact the IWPG at (614) 645-5876 for review of their project.

City of Columbus
Industrial Wastewater Pretreatment Group
1250 Fairwood Avenue, Room 186
Columbus, Ohio 43206
Attn: Interceptor Variance Requests
City of Columbus Industrial Wastewater Pretreatment Group: (614) 645-5876

It is highly recommended that application and the approval for the variance be obtained prior to submitting for plan review and approval as this request may place the approval 'on-hold'. Should the approval for a variance be obtained after plan approval, the owner must again submit revised drawings for review and approval. A revision fee will be assessed per the fee schedule.

City of Columbus. Division of Sewerage and Drainage
1145.04 (B) Variance Request Form

CIC #01
Page 3

(If handwritten, must be printed in ink and legible.)

Property Owner Name: _____

Food Service Name: _____

Business Address: _____

City, State, Zip Code: _____

Parcel Identification Number (PID): _____

Contact name: _____

Phone number(s): _____

E-mail: _____

Agency Issuing Plumbing Permit: _____

Check all that apply:

____ New Construction

____ Existing Structure

____ The property size is not adequate for an outside interceptor.

____ There are documented physical limitations with the property or structure that preclude installation of an outside interceptor.

____ The work encompassed by the plumbing permit does not affect kitchen function. This would include but not be limited to equivalent replacement of any kitchen fixtures and the addition or replacement of sanitary fixtures.

List any attachments: _____

If not fully addressed by the categories you checked above, explain why installation of an outside interceptor is impractical (you may use additional pages or the back of this form if you require additional space):

Signature: _____ Date: _____

Printed Name: _____



DEPARTMENT OF BUILDING
AND ZONING SERVICES

757 Carolyn Avenue
Columbus, Ohio 43224-3218

GREASE INTERCEPTOR DETERMINATION FORM

Project Address:

Tenant/Owner

Contact Number:

E-mail Address/Fax: _____

Owner:

Owner's Address:

Owner's Number:

E-mail Address/Fax: _____

Is the facility required to have a Food Service License or a Retail Food Establishment License?

Yes No

Is a three compartment sink required by the Health Department? Yes No

If yes what is the fixture used for? _____

Does the facility have a Type I exhaust hood for grease removal? Yes No

Indicate which plumbing fixtures receiving grease laden waste will be at the facility:

- Pot Sink (Three Compartment Sink)
- Soup Kettle
- Wok Station
- Commercial Dishwasher
- Automatic hood wash unit (Type I hood)
- Floor drain or floor sink used to dump kettles / grease
- Other _____

Identify if any of the following will be used

Dairy products served: _____

Meat cutting including cutting deli meats

Description of operation and provide a copy of the menu:

Based on the information provided above, the following determination is:

Grease separation is **required**.

For additional information concerning the management of grease, fats and oils see:

<http://utilities.columbus.gov/DOSD/FatsOilsGrease.htm>

- A gravity grease interceptor is required
- A hydromechanical grease interceptor is acceptable.

A grease interceptor is **not** required

Date: _____

Amit Ghosh Chief Building Official:
By Assistant Chief Building Official
City of Columbus
757 Carolyn Ave.
Columbus, Ohio 43224
614/645-3984 Fax 614/645-7840
greaseinterceptor@columbus.gov

Required Direct and Indirect Connections to the Building Drainage System

Requirements: Section 802.1.1 of the OPC requires equipment and fixtures utilized for the storage, preparation and handling of food to be discharged through an indirect waste pipe by means of an air gap. Section 1003.3.1 of the OPC requires a grease interceptor or automatic grease removal device receive the drainage from fixtures and equipment with grease-laden waste located in food preparation areas.

Memorandum: In order to eliminate confusion as to which fixtures require direct or indirect connection to a building drainage system as well as which fixtures the City of Columbus permits and or requires to be connected to a grease interceptor, the following shall clarify these issues:

Only plumbing fixtures, which discharge fats, oils or grease-laden waste located in food preparation areas shall be connected to the grease interceptor per Section 1003.3.1 of the OPC.

The following plumbing fixtures shall be connected to a grease interceptor or a grease waste line:

- Pots and pans sinks (3-compartment may be directly or indirectly connected)
- Prerinse sinks
- Soup kettles and adjacent floor drain or floor sink
- Wok stations
- Food waste grinder (**requires solids separator/strainer**)
- Automatic hood wash units and dishwashers with or without prerinse sinks
- Floor drains associated with fryers, griddles or meat processing

The following plumbing fixtures shall be indirectly connected to the sanitary drainage system:

- Sinks used for food preparation
- Refrigerated cases and cabinets
- Ice boxes and ice making machines
- Steam kettles and steam tables
- Potato peelers and egg boilers
- Coffee urns and brewers
- Drink dispensers and similar equipment
- Floor drains located in food storage areas or freezers shall comply with OPC 802.1.2
- 3 compartment sinks used in bar areas exclusively for washing, rinsing and sanitizing beverage glasses

All businesses licensed for food service shall have a food service plan review performed and approved by Columbus Public Health prior to plan submittal to Building and Zoning Services, for more information please contact:

Columbus Public Health: Ebony Merritt - (614) 645-6191

Building and Zoning Services Plan Review – (614) 645-7562