


**NOTES:**

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. THIS PORTION OF PIPE EMBEDMENT ZONE MUST BE RECOMPACTED TO PROPER DENSITIES AFTER MOVING SUPPORT SYSTEM FORWARD.
3. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
4. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.12.

L-6309B Revision Date: 3/4/13

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	<b>STANDARD DETAIL</b> <b>TYPICAL TRENCH</b> EXCAVATION & BACKFILL OUTSIDE INFLUENCE OF PAVEMENT (FOR 16" DIAMETER WATER MAIN AND SMALLER)	
APPROVED: <i>R.C. Westerfield</i> ADMINISTRATOR	5-14-13 DATE	