



MAIN LINE	DIMENSION "L"
	TYPE "A"
6"	39"
8"	40"
12"	43"
16"	46"
20"	58"
24"	61"
30"	64"

**NOTES:**

1. FIRE HYDRANT SHALL HAVE A MAXIMUM BURY OF 7'-0". MODIFICATION OF THE HYDRANT LEAD TO MEET THIS REQUIREMENT SHALL BE IN THAT SECTION FROM THE VALVE TO THE HYDRANT AS PER STANDARD DETAIL L-7601.
2. FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
3. TEE USED TO CONNECT HYDRANT LEAD TO WATER MAIN IS INCLUDED IN COST OF ITEM 809, FIRE HYDRANT.

CITY OF COLUMBUS  
 DEPARTMENT OF PUBLIC UTILITIES  
 DIVISION OF WATER

APPROVED:  
*R.C. Wasterfield* 5-16-13  
 ADMINISTRATOR DATE

STANDARD DETAIL  
 TYPICAL TYPE "A" HYDRANT SETTING  
 FOR DUCTILE IRON  
 MECHANICAL JOINT x SWIVEL TEES

