



MAIN LINE	DIMENSION "L"
	TYPE "A"
20"	58"
24"	61"
30"	64"
36"	68"
42"	71"
48"	74"

NOTES:

1. FIRE HYDRANT SHALL HAVE A MAXIMUM BURY OF 7'-0". MODIFICATION OF THE HYDRANT LEAD TO MEET THIS REQUIREMENT SHALL BE IN THAT SECTION FROM THE VALVE TO THE HYDRANT AS PER STANDARD DETAIL L-7601.
2. FIRE HYDRANTS SHALL BE SET A MINIMUM OF 6' FROM ALL DRIVEWAY OPENINGS.
3. TEE USED TO CONNECT HYDRANT LEAD TO WATER MAIN IS INCLUDED IN COST OR ITEM 809, FIRE HYDRANT.

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
R.C. Westerfield
 ADMINISTRATOR

5-16-13
 DATE

STANDARD DETAIL
 TYPICAL TYPE "A" HYDRANT SETTING
 FOR CONCRETE AND STEEL PIPE

