



**NOTE:** Water Service Lines shall be laid with a min. of 42" cover.

Adapter as required

Proposed Utility

Curb Stop \*

Cut ex. water service pipe and reconnect with adapter as required to new curb stop.

Variable \*\*

\* **NOTE:**  
For reference in placing new curb stops and relocated curb boxes see L-9901.

\*\* **NOTE:**  
Should Poly tubing, Galvanized or Lead material be encountered the entire Service Line shall be replaced w/ Copper from the existing Corporation Stop to the new Curb Stop. Pipe Shall Be Copper Tubing Size (C.T.S.).

L-7102C.Dwg. Revision. Date: 10/30/15

CITY OF COLUMBUS  
DEPARTMENT OF PUBLIC UTILITIES  
DIVISION OF WATER

APPROVED:  
*R C Westerfield* 11-5-15  
ADMINISTRATOR DATE

STANDARD DETAIL  
WATER SERVICE  
RELOCATION

