



**NOTES:**

1. Vertical Bends Shall Be 11 1/4", 22 1/2" or 45"
2. Where "D" is 18" or Less, a Mechanical Joint Ductile Iron Offset may be used in lieu of the two Vertical Bends and the Inclined Nipple, as Approved by the Engineer.
3. Fire Hydrants shall be set a minimum of 6' from all Driveway Radius Returns.
4. All Bends are to be Included in the Cost of Item 801.
5. No Hydrant Extensions Will be Permitted without Prior Approval from DOW.

CITY OF COLUMBUS  
DEPARTMENT OF PUBLIC UTILITIES  
DIVISION OF WATER

APPROVED:

*R.C. Westerfield* 5-16-13  
ADMINISTRATOR DATE

STANDARD DETAIL  
TYPICAL HYDRANT SETTING  
(TO ELIMINATE EXCESSIVE BURY)

