



Note:

- 1) Add Snap Ring or Harness Restrained Joints and Anchored M.J.S. Joints to Adapters located in restrained areas when Restrained Joints are required on Plans.
- 2) Paint all exposed steel with Hi-Build White Epoxy Paint Coating.

L-7602.Dwg Revision Date: 2/8/12

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF POWER & WATER	
APPROVED: <i>R.C. Westerfield</i> ADMINISTRATOR	<i>2-9-12</i> DATE

STANDARD DETAIL CONCRETE PIPE VALVE PIPING CONNECTION

