



NOTES:

1. THE PENETRATION IN THE MAIN SEWER SHALL BE CORED FOR THE DIAMETER REQUIRED FOR THE FLEXIBLE CONNECTOR. DOES NOT APPLY TO FABRICATED OR MOLDED FITTINGS. THE FLEXIBLE CONNECTOR SHALL BE FROM THE CITY OF COLUMBUS APPROVED SUPPLIERS LIST.
2. PIPE MATERIALS SHALL BE IN CONFORMANCE WITH 901.02.
3. BEGINNING OF BELL SECTION OF STUB PIPE TO BE FLUSH WITH END OF FLEXIBLE CONNECTOR.
4. STUB PIPE SHALL NOT EXTEND INTO MAIN SEWER.
5. VERTICAL RISER MAY LAY AGAINST UNDISTURBED SOIL.

CITY OF COLUMBUS, OHIO
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF SEWERAGE & DRAINAGE

[Signature]
 SSES MANAGER

TYPICAL CORED
 RISER DETAIL
 (FLEXIBLE SEWER)

STANDARD DRAWING AA-S162
REVISED 10/12/21
PAGE 1 / 1