



NOTES:

1. **GENERAL:** THE CONTRACTOR SHALL ADVISE THE ENGINEER OF ALL PRIVATE DRAINS ENCOUNTERED IF CONNECTED TO A BUILDING, SEPTIC TANK, CESSPOOL, FILTER BED, TREATMENT PLANT OR IF DISCHARGING POLLUTED WATER OF ANY KIND.
2. SUCH DRAINS WILL EITHER BE CONNECTED TO THE DRAINAGE SYSTEM (REQUIRES OFFICIAL PERMIT) OR PLUGGED AS DIRECTED BY THE ENGINEER.
3. IF CONNECTED TO THE STORM SEWER SYSTEM, THE INSPECTION WELL SHALL BE CONSTRUCTED AS DETAILED HERE ON EACH SUCH DRAIN UNLESS THE DRAIN IS TO BE CONNECTED TO A CATCH BASIN, INLET OR MANHOLE OR IS TO DISCHARGE INTO AN OPEN CHANNEL OR DITCH.
4. THE COST OF TAPPING THE STORM SEWER, INCLUDING THE CONCRETE COLLAR OR TEE, SHALL BE INCLUDED IN THE UNIT PRICE BID PER FOOT OF ITEM 901 CONDUIT.
5. WHEN PVC PIPE IS USED FOR THE RISER SECTION OF THE INSPECTION WELL, FORM A RECESSED BELL AREA IN THE CONCRETE AT THE TOP OF THE WELL TO RECEIVE THE CAST IRON COVER.
6. COMPONENT PARTS OF THE INSPECTION WELL MAY BE JOB OR FACTORY CUT AND JOB ASSEMBLED.

CITY OF COLUMBUS, OHIO
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF SEWERAGE & DRAINAGE

INSPECTION WELL

STANDARD DRAWING
 AA-S174

REVISED 7/9/12

SSS MANAGER

John J. Newson

PAGE

1

1