



⚠ Solid Concrete Supports under all Valves and Meter Flanges, Solid Concrete Blocks may be used as well (Typical) (Shim with Hardwood as Needed)

L-9002G.Dwg Revision Date: 4/24/13

| | |
|---|-----------------|
| CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER | |
| APPROVED: <i>R.C. Westerfield</i> ADMINISTRATOR | 5-16-13 DATE |

STANDARD DETAIL
TYPICAL BACKFLOW
PREVENTER SETTING
(INSIDE BUILDING or HOT BOX)
2" THRU 12" METERS

