



WOOD POLE

ANCHOR-BASE POLE

(SEE NOTE 1)

EMBEDDED POLE

(SEE NOTE 1)

CABINET HEIGHT (A)	MOUNTING HEIGHT (B)
LESS THAN 36"	30" ± 3"
36" AND OVER	23" ± 3"

NOTES:

- 1. POWER AND CONTROLLER SERVICE FOR METAL POLES SHALL BE SIMILAR TO THAT SHOWN FOR THE WOOD POLE WITH THE EXCEPTION OF THE ATTACHMENT HARDWARE.

POWER SERVICE CONDUIT RISER FOR POLE MOUNTED CABINET

CITY OF COLUMBUS, OHIO
DEPARTMENT OF PUBLIC SERVICE
DIVISION OF DESIGN AND CONSTRUCTION

[Signature]
CITY ENGINEER

STD DWG
4052
8/10/2017
SHT 1 OF 1