

## Ohio Building Code

*102.10 Work exempt from approval. Approval shall not be required for the following:*

### ***Building:***

1. One-story detached accessory structures used as tool and storage sheds, playhouses and similar uses, provided the floor area does not exceed one hundred twenty square feet ( 11.15 m<sup>2</sup>) and playground structures.
2. Fences not over six feet (1829 mm) high.
3. Retaining walls which are not over four feet (1219 mm) in height measured from the bottom of the footing to the top of the wall, unless supporting a surcharge or impounding Class I, II or III-A liquids.
4. Water tanks supported directly upon grade if the capacity does not exceed five thousand gallons (18 927 L) and the ratio of height to diameter or width does not exceed two to one.
5. Sidewalks and driveways not more than thirty inches (762 mm) above grade and not over any basement or story below and which are not part of an accessible route.
6. Finishes not regulated by this code, decorating, or other work defined as maintenance or minor repair.
7. Temporary motion picture, television and theater stage sets and scenery.
8. Window awnings supported by an exterior wall of Group R-3.
9. Tents and membrane structures exempted in section 3103.1.3.
10. Above-ground storage tanks as defined in rule [4101:1-2-01](#) of the Administrative Code and the associated tank foundations.
11. Battery operated smoke or carbon monoxide alarms installed in existing buildings where no construction is taking place.

### ***Electrical:***

1. Minor repair work, including the replacement of lamps or the connection of approved portable electrical equipment to approved permanently installed receptacles.
2. Electrical equipment used for radio and television transmissions except equipment and wiring for power supply, and the installations of towers and antennas.

3. The installation of any temporary system required for the testing or servicing of electrical equipment or apparatus.
4. Electrical wiring, devices, appliances, apparatus or equipment operating at less than twenty-five volts and not capable of supplying more than fifty watts of energy, unless specifically addressed in this code.
5. Process equipment and the associated wiring on the load side of the power disconnect to the equipment.
6. Electrical wiring equipment not connected to building services equipment in and adjacent to natural or artificially made bodies of water as defined in Article 682 of NFPA 70 as referenced in Chapter 35.

***Gas:***

1. Portable heating appliances;
2. Replacement of any part that does not alter approval of equipment or make such equipment unsafe.
3. Gas distribution piping owned and maintained by public or municipal utilities and located upstream of the point of delivery.
4. Process equipment, including the associated tanks, foundations, and process piping. For combination building services/process or power piping systems, the power or process piping located downstream of the control valve which separates the process from the building services piping is exempt from approval.

***Mechanical:***

1. Portable heating appliances;
2. Portable ventilation equipment;
3. Portable cooling units;
4. Replacement of any part which does not alter its approval or make it unsafe;
5. Portable evaporative cooler;
6. Process equipment including the associated tanks, foundations, and process piping. For combination building services/process or power piping systems, the power or process piping located downstream of the control valve which separates the process from the building services piping is exempt from approval.

7. Heating and cooling distribution piping installed and maintained by public or municipal utilities.

***Plumbing:***

1. The repair of leaks in drains, water, soil, waste or vent pipe; provided, however, that if any concealed trap, drain-pipe, water, soil, waste or vent pipe becomes defective and it becomes necessary to remove and replace the same with new material, such work shall be considered as new work and an approval shall be obtained and inspection made as provided in this code.

2. The clearance of stoppages or the repair of leaks in pipes, valves or fixtures, and the removal and reinstallation of water closets, provided such repairs do not involve or require the replacement of more than one fixture or rearrangement of valves, pipes or fixtures.

3. Process equipment including the associated tanks, foundations, and process piping. For combination building services/process or power piping systems, the power or process piping located downstream of the control valve which separates the process from the building services piping is exempt from approval.