



**NOTE:**

1. OUTLET PIPE MAY BE LOCATED IN END OR SIDE WALL. IN EITHER CASE OUTLET PIPE TO BE DIRECTED TOWARDS CENTER OF BASIN.
2. ALL CONCRETE SHALL BE CLASS COC-6.
3. PRECAST UNITS SHALL BE IN ACCORDANCE WITH ASTM C913, HAVE A MINIMUM THICKNESS OF 6" AND BE REINFORCED SUFFICIENTLY TO PERMIT SHIPPING AND HANDLING WITHOUT DAMAGE.

CITY OF COLUMBUS, OHIO  
 DEPARTMENT OF PUBLIC UTILITIES  
 DIVISION OF SEWERAGE & DRAINAGE

PRECAST  
 RECTANGULAR  
 CATCH BASIN

STD. DWG.  
 AA-S135

REVISED 9/13/22

*[Signature]*  
 SSES MANAGER

PAGE

1

1