



**NOTES:**

- 1) CONTRACTOR SHALL PARGE 18" IN ALL DIRECTIONS AROUND THE PROPOSED, CORED CONNECTION. PARGING SHALL BE A MIN. OF 2" THICK AND CONFORM TO 901.15.B.1.b
- 2) THE PENETRATION IN THE MAIN SEWER SHALL BE CORED FOR THE DIAMETER REQUIRED FOR THE VITRIFIED CLAY PIPE.
- 3) PIPE STUB SHALL NOT EXTEND INTO MAIN SEWER (FLUSH).

CITY OF COLUMBUS, OHIO  
 DEPARTMENT OF PUBLIC UTILITIES  
 DIVISION OF SEWERAGE & DRAINAGE

BLIND TAP CONNECTION  
 TO EXISTING BRICK  
 SEWER  
 (48" AND LARGER)

STANDARD DRAWING  
 AA-S158

REVISED 9/6/22

APPROVED:

9/6/22

DATE

SSES MANAGER

PAGE

1

1