



**NOTES:**

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
3. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.13.
4. IF CONTAMINATED SOILS ARE ENCOUNTERED DURING EXCAVATION, CEASE DIGGING AND CONTACT THE DIVISION OF WATER DISTRIBUTION ENGINEERING SECTION.

L-1701A Revision Date: 5/12/22

CITY OF COLUMBUS DEPARTMENT OF PUBLIC UTILITIES DIVISION OF WATER	<b>STANDARD DETAIL</b> <b>TYPICAL TRENCH</b> EXCAVATION & BACKFILL UNDER INFLUENCE OF PAVEMENT (FOR 2" AND SMALLER WATER TAPS)	
APPROVED:  ADMINISTRATOR	9/21/22 DATE	