



BEDDING DEPTH	
6" AND 8" PVC	6"
<= 10' COVER, OTHER THAN PVC	0"
> 10' COVER	6"
UNSUITABLE MATERIAL OR ROCK	6"

**NOTES:**

1. REFER TO OSHA REQUIREMENTS FOR MAXIMUM ALLOWABLE TRENCH SLOPES.
2. PROVIDE FILTER FABRIC WHEN VERY FINE OR UNSTABLE MATERIAL IS ENCOUNTERED.
3. BACKFILL SHALL BE COMPACTED PER THE REQUIREMENTS OF ITEM 801.14.
4. IF CONTAMINATED SOILS ARE ENCOUNTERED DURING EXCAVATION, CEASE DIGGING AND CONTACT THE DIVISION OF WATER DISTRIBUTION ENGINEERING SECTION.

CITY OF COLUMBUS  
DEPARTMENT OF PUBLIC UTILITIES  
DIVISION OF WATER

APPROVED:

*[Signature]*  
ADMINISTRATOR

7/21/22  
DATE

STANDARD DETAIL  
**TYPICAL TRENCH**  
EXCAVATION & BACKFILL OUTSIDE  
INFLUENCE OF PAVEMENT  
(FOR 16" DIAMETER WATER MAIN AND SMALLER)

L-6309B