



CODED NOTES:

- (A) BOLT TRANSFORMER ON EACH SIDE OF PAD WITH MANUFACTURER SUPPLIED HOLD-DOWN CLEAT.
- (B) SECONDARY AND/OR SERVICE CABLES TO BE INSTALLED NEXT TO TRANSFORMER SO THEY DO NOT INTERFERE WITH THE MOVEMENT OF THE PRIMARY CABLES.

# OF HOLES	TRANSFORMER SIZE
4 MIN.	0-167 KVA
6 MIN.	167-250 KVA
8 MIN.	250-333 KVA

COMPATIBLE UNIT: TDMIS-3731.

TDMIS ID	MATERIAL	QTY	QTY	QTY	QTY
T1PM	SINGLE PHASE TRANSFORMER, SEE TDMIS-9071	1			
UR36	BUSHING WELL INSERT	2			
CCC2626	CONNECTOR, COMPRESSION TYPE, COPPER, 2/0 AWG TO 2/0 AWG TAP	3			
WPC4A	CONDUCTOR, COPPER, 2/0 AWG, 19 STRAND (FEET)	6			

 <p>THE CITY OF COLUMBUS DEPT. OF PUBLIC UTILITIES DIVISION OF POWER</p>	<p>SINGLE PHASE DEAD-FRONT PAD-MOUNTED TRANSFORMER</p>	<p>TDMIS-3731</p>
---	--	-------------------