



CODED NOTES:

- Ⓐ BOLT TRANSFORMER ON EACH SIDE OF PAD WITH MANUFACTURER SUPPLIED HOLD-DOWN CLEAT.
- Ⓑ SECONDARY AND/OR SERVICE CABLES TO BE INSTALLED NEXT TO TRANSFORMER SO THEY DO NOT INTERFERE WITH THE MOVEMENT OF THE PRIMARY CABLES.
- Ⓒ X2 TERMINAL STUD SHALL BE COVERED WITH TWO HALF LAPPED LAYERS OF INSULATING TAPE AND HALF-LAPPED LAYER OF JACKETING TAPE.
- Ⓓ RUN GROUND STRAP FROM CASE GROUND TO X1 BUSHING OR REMOVE STRAP AND INSTALL #4 FROM CASE GROUND TO X1 BUSHING.

# OF HOLES	TRANSFORMER SIZE
4 MIN.	0-167 KVA
6 MIN.	167-250 KVA
8 MIN.	250-333 KVA

COMPATIBLE UNIT: TDMIS-3734.

TDMIS ID	MATERIAL	QTY	QTY	QTY	QTY
T1PM	SINGLE PHASE TRANSFORMER, SEE TDMIS-9071	1			
UR36	BUSHING WELL INSERT	2			
CCC2626	CONNECTOR, COMPRESSION TYPE, COPPER, 2/0 AWG TO 2/0 AWG TAP	3			
WPC4A	CONDUCTOR, COPPER, 2/0 AWG, 19 STRAND (FEET)	6			

	<p>SINGLE PHASE PAD-MOUNTED TRANSFORMER FOR 480V STREET LIGHTING SERVICE</p>	<p>TDMIS-3734</p>
--	--	-------------------