

## **ALUMINUM ACCESS DOOR FOR 20' ALUMINUM STANDARD**

### I. Quantity

The base bid shall include the indicated number of aluminum access doors furnished and installed as hereinafter specified and located in the field as shown on the drawings.

### II. Material

The access shall be aluminum alloy 43F and be complete with a tamper resistant stainless steel locking screw. The access door shall fit the HAPCO aluminum standard #77-008.

### III. Installation

The aluminum access door shall be installed on the transformer base of the standard. Broken locking screws shall be removed and the transformer base shall be re-tapped if required.

### IV. Payment

The access doors for 20' aluminum standards as hereinbefore specified shall be quoted on as a unit price each in the appropriate place in this document.