

REFURBISH ALUMINUM LIGHT STANDARD

I. Quantity

The base bid shall include the indicated number of aluminum light standards refurbished as hereinafter specified at the locations shown on the drawings and as indicated in the field by the engineer.

II. Material

Shims - The "U" shims shall be aluminum.

III. Installation

The anchoring nuts shall be loosened and the standard shall be plumbed by the use of the shims. All nuts shall be securely re-tightened with the standard plumb before the new luminaire is installed.

Any other missing hardware such as anchoring nuts shall be replaced and included in the cost of the item. The ground wire connection shall be checked and re-tightened if required.

IV. Quotation

The refurbished aluminum light standard shall be quoted on as a unit price each in the appropriate place in this document.