



NOTE:
 Plan Designer shall be responsible to insure that all bends, tees, valves, meters and/or backflow prevention assembly lengths fit within the allotted space. Refer to Division of Water Standard Details "L-6317C & D", "L-9002A & B" for additional information.

NOTE:
 DOW installed radio transmitter outside building per L-6101.

NOTE:
 Blocking per L-6311

CITY OF COLUMBUS
 DEPARTMENT OF PUBLIC UTILITIES
 DIVISION OF WATER

APPROVED:
[Signature]
 ADMINISTRATOR

11-17-23
 DATE

STANDARD DETAIL
 TYPICAL METER SETTING
 WITH BACKFLOW PREVENTER
 (INSIDE BUILDING ONLY)
 3" THRU 12" METERS

