KRISTEN ATHA
Director

COLUMBUS WATER & POWER

This document is not the original document. This document was recreated to achieve compliance with 28 C.F.R. Part 35 (web content and mobile app accessibility). A copy of the original document is available upon request.

RULES AND REGULATIONS
Division of Water
Department of Public Service

July 14th, 1969
Recreated on: September 17th, 2026

RE: VALVING ON TAPS LARGER THAN 2-INCH

Effective immediately all taps totally or partially under pavement shall have two valves. One value at the main and the second valve outside the pavement on the applicant's side of the right-of-way. The tap shall be considered as that portion extending from the mainline through both valves. The tap shall be owned and maintained by the City of Columbus. All service lines after the second valve regardless of the amount within the right-of-way shall be owned and maintained by the property owner.

All taps where none of the tap is under pavement or traveled portion of the right-of-way shall be constructed using only one valve. The City of Columbus shall own and maintain that portion of the tap through the valve. All service line after the valve shall be owned and maintained by the property owner regardless of the amount of service line within the public right-of-way.

None of the above shall effect the requirements for taps 2-inch and smaller which require the use of a corporation stop and curb stop with box.

RCP: FHW: nc

Franklin H. Wright, Superintendent
Division of Water

Approved by:

W.J. Cremean, Director
Department of Public Service

Maynard E. Sensenbrenner, Mayor