

I. REMOVAL

THE OLD FOUNDATION SHALL BE ENTIRELY REMOVED TO MAKE ROOM FOR THE NEW FOUNDATION. IF A NEW FOUNDATION IS NOT REQUIRED, THE FOUNDATION SHALL BE REMOVED TO AT LEAST ONE FOOT BELOW THE GROUND SURFACE AND THE HOLE BACKFILLED. THE BACKFILL SHALL BE PLACED PER CITY OF COLUMBUS CONSTRUCTION AND MATERIAL SPECIFICATIONS SECTION 911.01-911.05 AND SITE RESTORATION SHALL BE COMPLETED PER CMS SECTION 104.07, AS WELL AS ITEM 659 WHERE NOTED.

THE CONCRETE SHALL BE DISPOSED OF BY THE CONTRACTOR IN ACCORDANCE WITH CITY OF COLUMBUS CONSTRUCTION AND MATERIAL SPECIFICATIONS.

IF THE OLD FOUNDATION IS LOCATED IN A SIDEWALK, THE FOUNDATION SHALL BE REMOVED PER ABOVE AND THE SECTION OF THE SIDEWALK SHALL BE REPLACED. REFER TO CITY OF COLUMBUS, DEPARTMENT OF PUBLIC SERVICE STD DWG 1441 FOR SIDEWALK REPLACEMENT.

SITE RESTORATION IS CONSIDERED TO BE A PART OF THIS ITEM, AND NO ADDITIONAL PAYMENT WILL BE MADE OUTSIDE THIS SPECIFICATION. ANY SITE RESTORATION NOT COMPLETED IMMEDIATELY AFTER THE FOUNDATION REMOVAL WILL REQUIRE THE AREA TO BE BARRICADED IN PLACE UNTIL BACKFILL AND RESTORATION CAN BE COMPLETED.

II. BASIS OF PAYMENT

ITEM	UNIT	DESCRIPTION
MIS-900	EACH	FOUNDATION REMOVAL

MIS-900	DEPARTMENT OF PUBLIC UTILITIES - DIVISION OF POWER CITY OF COLUMBUS, OHIO		
	FOUNDATION REMOVAL		
	DRAWN BY: SAW	DATE: 12/21/23	
	SCALE: NONE	SHEET: 1 OF 1	900