

## City of Columbus UCMR 5 Monitoring Results

**PFAS compounds included in recently established U.S. EPA National Primary Drinking Water Rules.**

			Dublin Road Water Plant		Hap Cremean Water Plant		Parsons Avenue Water Plant	
Substance	Final MCLG (ppt)	Final MCL (ppt)	Range of Detections	Level Found	Range of Detections	Level Found	Range of Detections	Level Found
PFOA	0	4	ND – 5.3ppt	1.3 ppt	ND	ND	ND	ND
PFOS	0	4	ND	ND	ND	ND	ND	ND
PFHxS	10	10	ND	ND	ND	ND	ND	ND
PFNA	10	10	ND	ND	ND	ND	ND	ND
GenX (HPFO-DA)	10	10	ND	ND	ND	ND	ND	ND
Two or more of the following in combination: PFBS PFHxS PFNA GenX	Hazard Index = 1		ND – 0.006	ND – 0.001	ND	ND	ND	ND

**PFAS compounds not included in recently established U.S. EPA National Primary Drinking Water Rules. The following PFAS compounds are unregulated.**

PFBA	NA	NA	ND-17.0 ppt	7.4ppt	ND	ND	ND-6 ppt	3 ppt
PFPeA	NA	NA	ND-14.2 ppt	4.3 ppt	ND	ND	ND-3.3 ppt	1.7 ppt
PFHpA	NA	NA	ND-4.3 ppt	1.1 ppt	ND	ND	ND	ND
PFHxA	NA	NA	ND-18.2 ppt	6.7 ppt	ND	ND	ND	ND

**ND = Non-detect below the UCMR minimum reporting level**